



SIMATIC ET 200SP HA, PROFINET interface module IM155-6 PN max. 56 I/O modules, multi-hot swap, without server module

| General information                                      |  |
|--|--|
| Product type designation                                 | IM 155-6 PN  |
| HW functional status                                     | FS03   |
| Firmware version   | V1.1   |
| Vendor identification (VendorID)                         | 02AH   |
| Device identifier (DeviceID)                             | 030FH  |
| Product function   |  |
| • I&M data   | Yes; I&M0 to I&M3  |
| Engineering with   |  |
| • STEP 7 TIA Portal configurable/integrated from version | V16  |
| • STEP 7 configurable/integrated from version            | V5.6   |
| • PCS 7 configurable/integrated from version             | V9.0   |
| • PCS neo can be configured/integrated from version      | V3.0   |
| Configuration control                                    |  |
| via dataset  | No   |
| Supply voltage   |  |
| Rated value (DC)   | 24 V   |
| permissible range, lower limit (DC)                      | 19.2 V   |
| permissible range, upper limit (DC)                      | 28.8 V   |
| Reverse polarity protection                              | Yes  |
| Short-circuit protection                                 | Yes  |
| Mains buffering  |  |
| • Mains/voltage failure stored energy time               | 10 ms  |
| Input current  |  |
| Current consumption, max.                                | 700 mA; +19.2 V to +28.8 V DC  |
| Inrush current, max.                                     | 5 A  |
| I <sup>2</sup> t   | 0.36 A <sup>2</sup> ·s; Due to increased mains buffering of 10 ms                      |
| Power  |  |
| Infeed power to the backplane bus                        | 7.5 W; no doubling in redundant mode as the infeed power is also designed as redundant |
| Power loss   |  |
| Power loss, typ.   | 2.4 W  |
| Address area   |  |
| Address space per module                                 |  |
| • Address space per module, max.                         | 256 byte   |
| Address space per station                                |  |
| • Address space per station, max.                        | 1 440 byte; 1 440 bytes R1 and S1 without CiR, otherwise 1 000 bytes                   |
| Hardware configuration                                   |  |
| Integrated power supply                                  | Yes; 24 V DC   |

|  |  |
|--|--|
| <b>Rack</b>                                      |  |
| • Modules per rack, max.                         | 56; 56 slots for I/O modules + server module (width without IM ≤ 1.3 m)                  |
| <b>Time stamping</b>                             |  |
| Accuracy   | 1 ms; In compliance with the supplementary conditions described in the Equipment Manual  |
| <b>Interfaces</b>                                |  |
| Number of PROFINET interfaces                    | 1; 2 ports (switch)  |
| <b>1. Interface</b>                              |  |
| <b>Interface types</b>                           |  |
| • Number of ports                                | 2; via BusAdapter  |
| • integrated switch                              | Yes  |
| • BusAdapter (PROFINET)                          | Yes; Compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x LC, BA LC/RJ45, BA LC/FC, BA VD |
| <b>Protocols</b>                                 |  |
| • PROFINET IO Device                             | Yes  |
| • Open IE communication                          | Yes  |
| • Media redundancy                               | Yes; as MRP client   |
| <b>Interface types</b>                           |  |
| <b>RJ 45 (Ethernet)</b>                          |  |
| • Transmission procedure                         | PROFINET with 100 Mbit/s full duplex (100BASE-TX)  |
| • 100 Mbps                                       | Yes; PROFINET with 100 Mbit/s full duplex (100BASE-TX)                                   |
| • Autonegotiation                                | Yes  |
| • Autocrossing                                   | Yes  |
| <b>Protocols</b>                                 |  |
| <b>Redundancy mode</b>                           |  |
| • PROFINET system redundancy (S2)                | Yes; S2, R1  |
| <b>Media redundancy</b>                          |  |
| — MRP  | Yes  |
| <b>Open IE communication</b>                     |  |
| • TCP/IP   | Yes  |
| • SNMP   | Yes  |
| • LLDP   | Yes  |
| <b>Interrupts/diagnostics/status information</b> |  |
| Status indicator                                 | Yes  |
| Alarms   | Yes  |
| Diagnostics function                             | Yes  |
| <b>Diagnostics indication LED</b>                |  |
| • RUN LED  | Yes; green LED   |
| • ERROR LED                                      | Yes; red LED   |
| • MAINT LED                                      | Yes; Yellow LED  |
| • ACT LED  | Yes; green LED   |
| • Monitoring of the supply voltage (PWR-LED)     | Yes; green PWR LED   |
| • Connection display LINK TX/RX                  | Yes; 2x green link LEDs on BusAdapter  |
| <b>Potential separation</b>                      |  |
| between PROFINET and all other circuits          | Yes; 1 500 V AC  |
| between supply and all other circuits            | Yes; Type tested with 1 500 V DC   |
| <b>Permissible potential difference</b>          |  |
| between different circuits                       | Safety extra low voltage SELV  |
| <b>Isolation</b>                                 |  |
| Isolation tested with                            | 1 500 V DC/1 min, type test  |
| <b>Ambient conditions</b>                        |  |
| <b>Ambient temperature during operation</b>      |  |
| • horizontal installation, min.                  | -40 °C   |
| • horizontal installation, max.                  | 70 °C  |
| • vertical installation, min.                    | -40 °C   |
| • vertical installation, max.                    | 60 °C  |
| <b>Dimensions</b>                                |  |
| Width  | 50 mm  |
| Height   | 138 mm   |
| Depth  | 89 mm  |
| <b>Weights</b>                                   |  |

Weight, approx.

192 g; without BusAdapter

**last modified:**

3/2/2021 