SIEMENS

Data sheet 6GK1161-6AA02

product type designation



CP 1616

Communications processor CP 1616 PCI card (32-bit; 33/66 MHz; 3.3/5 V) with asic ERTEC 400 for connection to PROFINET IO with 4-port real-time switch (RJ45) via development kit DK-16XX PN IO; NCM PC.

transfer rate	
transfer rate	100 Mbit/s
interfaces	
number of electrical connections	
 at the 1st interface / according to Industrial Ethernet 	4
for power supply	1
type of electrical connection	
 at the 1st interface / according to Industrial Ethernet 	RJ45 port
 of the backplane bus 	PCI (32Bit 3,3V/5V UniversalKey 33/66MHz)
for power supply	Low-voltage socket for hollow plug 3.5 mm (-) / 1.3 mm (+)
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage	
1 / from backplane bus	5 V
external	6 9 V
relative symmetrical tolerance / at DC	
• at 5 V	5 %
• at 12 V	5 %
consumed current	
1 / from backplane bus / at DC / maximum	0.8 A
from external supply voltage / at DC / at 6 V / maximum	0.65 A
• from external supply voltage / at DC / at 9 V / maximum	0.45 A
power loss [W]	4 W
power loss [W] / in switch mode / maximum	4.1 W
ambient conditions	
ambient temperature	
 during operation 	5 70 °C
during storage	-40 +60 °C
during transport	-20 +60 °C
relative humidity / at 25 °C / without condensation / during operation / maximum	95 %
protection class IP	IP00
design, dimensions and weights	
module format	PCI
width	18 mm
height	107 mm
depth	167 mm
net weight	110 g
product features, product functions, product components / gen	neral

number of plug-in cards of same design / plug-in / per PC	1
station number of units / note	-
performance data / PROFINET communication / as PN IO contro	
software / for PROFINET IO communication / required number of PN IO devices / on PROFINET IO controller /	No 128
operable / total number of PN IO IRT devices / on PROFINET IO controller /	64
operable data volume	
as user data for input variables / as PROFINET IO controller / maximum	8192 byte
 as user data for output variables / as PROFINET IO controller / maximum 	8192 byte
 as user data for input variables per PN IO device / as PROFINET IO controller / maximum 	1430 byte
 as user data for output variables per PN IO device / as PROFINET IO controller / maximum 	1430 byte
performance data / PROFINET communication / as PN IO device	
data volume	
• as user data for input variables / as PROFINET IO device / maximum	1430 byte
 as user data for output variables / as PROFINET IO device / maximum 	1430 byte
 as user data for input variables / for each sub-module as PROFINET IO device 	254 byte
as user data for output variables / for each sub-module as PROFINET IO device	254 byte
as user data for the consistency area for each sub- module	254 byte
number of submodules / per PROFINET IO-Device	64
product functions / management, configuration, engineering	
product function / MIB support	Yes
protocol / is supported	
• SNMP v1	Yes
• DCP	Yes
• LLDP	V
	Yes
configuration software / required	Included in scope of supply
configuration software / required	
configuration software / required identification & maintenance function	Included in scope of supply
configuration software / required identification & maintenance function • I&M0 - device-specific information	Included in scope of supply Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation	Included in scope of supply Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date	Included in scope of supply Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment	Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature	Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data	Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics	Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function	Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics	Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch	Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product feature / switch	Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed	Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product feature / switch product function / switch-managed product function / with IRT / PROFINET IO switch	Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product feature / switch product function / switch-managed product function / with IRT / PROFINET IO switch product functions / redundancy	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes No Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product feature / switch product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required	Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes No Yes No
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function • ring redundancy	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes No Yes No Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product feature / switch product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function • ring redundancy manager	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product feature / switch product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function • ring redundancy • redundancy manager protocol / is supported / Media Redundancy Protocol (MRP)	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes No Yes No Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function • ring redundancy • redundancy manager protocol / is supported / Media Redundancy Protocol (MRP) standards, specifications, approvals	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function • ring redundancy • redundancy manager protocol / is supported / Media Redundancy Protocol (MRP) standards, specifications, approvals reference code	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed product function / with IRT / PROFINET IO switch product function / with IRT / product function / required product function • ring redundancy • redundancy manager protocol / is supported / Media Redundancy Protocol (MRP) standards, specifications, approvals reference code • according to IEC 81346-2:2019	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Xes X
configuration software / required identification & maintenance function • I&M0 - device-specific information • I&M1 - higher level designation/location designation • I&M2 - installation date • I&M3 - comment • I&M4 - signature • I&M4 - OEM data product functions / diagnostics product function • web-based diagnostics • port diagnostics product functions / switch product function / switch-managed product function / with IRT / PROFINET IO switch product functions / redundancy software / for redundancy function / required product function • ring redundancy • redundancy manager protocol / is supported / Media Redundancy Protocol (MRP) standards, specifications, approvals reference code	Included in scope of supply Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes No Yes No Yes KEC

global warming potential [CO2 eq] 146.03 kg · during manufacturing 33.23 kg during operation 112.74 kg • after end of life 0.06 kg further information / internet links internet link • to website: Selection guide for cables and connectors https://support.industry.siemens.com/cs/ww/en/view/109766358 • to web page: selection aid TIA Selection Tool https://www.siemens.com/tstcloud • to website: Industrial communication https://www.siemens.com/simatic-net • to web page: SiePortal https://sieportal.siemens.com/ • to website: Image database https://www.automation.siemens.com/bilddb • to website: CAx-Download-Manager https://www.siemens.com/cax https://support.industry.siemens.com • to website: Industry Online Support security information security information Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7) Approvals / Certificates **General Product Approval EMV Environment Declaration of Con-KC** Confirmation formity **Industrial Communication PROFINET**

last modified: 8/8/2024 🖸