

Maintenance schedule for ACS580, ACH580 and ACQ580 drives



Recommended maintenance intervals and component replacements are based on specified operational and environmental conditions. ABB recommends annual drive inspections to ensure the highest reliability and optimum performance.

Note

Long term operation near or over the maximum specified ratings or environmental conditions may require shorter maintenance intervals. Check the device specific technical specifications in the relevant hardware manual and consult your local ABB Service for maintenance recommendations at: [/new.abb.com/channel-partners/search](https://new.abb.com/channel-partners/search)

More detailed maintenance information can be found in maintenance instructions, product manuals and on the Internet: [/new.abb.com/drives](https://new.abb.com/drives)

See the below listed technical notes for more details on component aging and possible effects on the drive.

Electrolytic capacitors	4FPS10001015180
Film capacitors	4FPS10001454838
Cooling fans	4FPS10001147616
PCBAs	4FPS10001147621
Power supplies	4FPS10001454842

For drives manufactured or maintained 2017 and onwards

ACS580-01/-04, ACH580-01/-04/-31/-34 and ACQ580-01/-04/-31/-34

ACS580-07, ACH580-07, ACQ580-07 Cabinet Drives

FUNCTIONAL SAFETY ACTIONS

Safety function test interval	I	The drive can be a part of a safety system or application which requires periodic testing. The customer defines the test interval of the complete safety system or application. Use this test interval to test the safety function.
Safety component expiry (Mission time T_M) 20 years	R	The mission time of the ABB LV AC drive safety component is 20 years in the safety data of the drive product. The safety data is introduced in the product hardware manual.

RECOMMENDED ACTIONS BY THE USER	Years from startup																				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Connections and environment																					
Cabinet door filters IP54	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R
Quality of supply voltage	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P
Spare parts																					
Spare parts inventory	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
DC circuit capacitors reforming, spare modules and spare capacitors	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P
Inspections by user																					
IP22 and IP42 air inlet and outlet meshes	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Tightness of terminals	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Dustiness, corrosion and temperature	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Heat sink cleaning	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Other																					
ABB-SACE Air circuit breaker maintenance	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
ABB Contactors maintenance	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
⁽¹⁾ Control unit (CCU/ZCU/UCU) condition	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I

⁽¹⁾ In harsh environmental conditions (heat/dust), control unit replacement is recommended after 12 years of operation time

Legend

- I Inspection (visual inspection and maintenance action if needed)
- P Performance of on/off-site work (commissioning, tests, measurements, or other work)
- R Replacement

DOCUMENT ID	REV	DATE	SECURITY LEVEL	LANG	PAGE
4FPS10000309652	R	07.08.2025	External	EN	2 / 6
(C) Copyright 2025 ABB, all rights reserved					

COOLING
Years from startup

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Fans, IP21 frames R0 to R9, R9e																					
Main cooling fans R0-R5						R						R						R			
Main cooling fans R6-R9, R9e LONGLIFE									R									R			
Auxiliary cooling fan for circuit boards, R4v2 89A/IP21 & R4v2 77A/IP21, R5v2						R						R						R			
Auxiliary cooling fan for circuit boards, only R5 - R9, R9e LONGLIFE									R									R			
Fans, IP55 frames R0 to R9, R9e																					
Main cooling fans R0-R5						R						R						R			
Main cooling fans R6-R9, R9e LONGLIFE									R									R			
Auxiliary cooling fan for circuit boards R0-R2 (Main fan on Bottom)			R			R			R			R			R			R			R
Auxiliary cooling fan for circuit boards R1-R2 (Main fan on Top)						R						R						R			
Auxiliary cooling fan for circuit boards R3, R4 LONGLIFE									R									R			
Auxiliary cooling fan for circuit boards R4v2, R5v2						R						R						R			
Auxiliary cooling fan(s) for circuit boards R5-R9, R9e LONGLIFE									R									R			
Auxiliary cooling fan in IP55 cover, only R8 and R9 LONGLIFE									R									R			
Auxiliary cooling fan in IP55 cover R9e									R									R			
Fans, ACH580-31, ACQ580-31 frames R3, R6, R8																					
Main cooling fans LONGLIFE									R									R			
Auxiliary cooling fans LONGLIFE									R									R			
Fans, frames R10 and R11																					
⁽¹⁾ Main cooling fans									R									R			
Circuit board compartment cooling fans LONGLIFE									R									R			
Cabinet cooling fan R6 to R9																					
Cabinet cooling fan, door (IP21, IP42, IP54)									R									R			
Cabinet cooling fan R10 to R11																					
Internal LONG-LIFE 50Hz									R									R			
Internal LONG-LIFE 60Hz						R						R						R			
Door LONG-LIFE 50 Hz									R									R			
Door LONG-LIFE 60Hz									R									R			
⁽¹⁾ IP54 50Hz									R									R			
⁽¹⁾ IP54 60Hz						R						R						R			
Cabinet cooling fan IP54									R									R			

⁽¹⁾ Fan has been always "LONG-LIFE" type

Legend

- I Inspection (visual inspection and maintenance action if needed)
- P Performance of on/off-site work (commissioning, tests, measurements, or other work)
- R Replacement

DOCUMENT ID	REV	DATE	SECURITY LEVEL	LANG	PAGE
4FPS10000309652	R	07.08.2025	External	EN	3 / 6
(C) Copyright 2025 ABB, all rights reserved					

AGING

Years from startup

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Control panel battery																					
Control panel battery									R									R			
⁽²⁾ Cabinet auxiliary 24VDC power supplies and buffers												R									
Frequency converter frames R6 to R9 (Except ACH580-31 & ACQ580-31 R6)																					
DC circuit electrolytic capacitors and discharging resistors									R									R			
Module internal circuit boards ZINT, ZPOW, ZINP, QINT												R									
DC busbar									R									R			
Frequency converter frames R9e																					
DC circuit electrolytic capacitors									R									R			
Module internal circuit boards ZINT, ZPOW, ZINP												R									
Frequency converter ACH580-31 & ACQ580-31 R6 HW 2																					
DC capacitor board QCAP									R									R			
Frequency converter frames R10 to R11																					
Flat ribbon cables												R									
DC circuit electrolytic capacitors and discharging resistors									R									R			
Module internal circuit boards BPOW / ZPOW												R									
Module internal circuit boards BFPS, BGDR, ZBDR, ZINT, BINT												R									

⁽²⁾ Check amount and types of Auxiliary power supplies from cabinet or manufactured BOM.

Legend

- I Inspection (visual inspection and maintenance action if needed)
- P Performance of on/off-site work (commissioning, tests, measurements, or other work)
- R Replacement

DOCUMENT ID	REV	DATE	SECURITY LEVEL	LANG	PAGE
4FPS10000309652	R	07.08.2025	External	EN	4 / 6
(C) Copyright 2025 ABB, all rights reserved					

For drives manufactured 2016 or before

ACS580-01/-04, ACH580-01 and ACQ580-01 Drives

ACS580-07 Cabinet Drives

FUNCTIONAL SAFETY ACTIONS

Safety function test interval	I	The drive can be a part of a safety system or application which requires periodic testing. The customer defines the test interval of the complete safety system or application. Use this test interval to test the safety function.
Safety component expiry (Mission time T_M) 20 years	R	The mission time of the ABB LV AC drive safety component is 20 years in the safety data of the drive product. The safety data is introduced in the product hardware manual.

RECOMMENDED ACTIONS BY THE USER

	Years from startup																				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Connections and environment																					
Quality of supply voltage	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P
Spare parts																					
Spare parts inventory	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
DC circuit capacitors reforming, spare modules and spare capacitors	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P
Inspections by user																					
Tightness of terminals	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Dustiness, corrosion and temperature	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Heat sink cleaning	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
Other																					
ABB-SACE Air circuit breaker maintenance	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
ABB Contactors maintenance	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
⁽¹⁾ Control unit (CCU) condition	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I

⁽¹⁾ In harsh environmental conditions (heat/dust), control unit replacement is recommended after 12 years of operation time

COOLING

	Years from startup																				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Fans, IP21 frames R0 to R9																					
Main cooling fans						R						R						R			
Auxiliary cooling fan for circuit boards, only R5 to R9			R			R			R			R			R			R			R
Fans, IP55 frames R0 to R9																					
Main cooling fans						R						R						R			
Auxiliary cooling fan for circuit boards			R			R			R			R			R			R			R
Auxiliary cooling fan in IP55 cover, only R8 and R9			R			R			R			R			R			R			R
Fans, frames R10 and R11																					
Main cooling fans									R									R			
Cooling fans for circuit board compartment						R						R						R			
Cabinet cooling fan R10 to R11																					
Internal 50Hz						R						R						R			
Internal 60Hz			R			R			R			R			R			R			R
Door 50 Hz						R						R						R			
Door 60Hz						R						R						R			
IP54 50Hz									R									R			
IP54 60Hz						R						R						R			

Legend

- I Inspection (visual inspection and maintenance action if needed)
- P Performance of on/off-site work (commissioning, tests, measurements, or other work)
- R Replacement

DOCUMENT ID	REV	DATE	SECURITY LEVEL	LANG	PAGE
4FPS10000309652	R	07.08.2025	External	EN	5 / 6
(C) Copyright 2025 ABB, all rights reserved					

AGING

Years from startup

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Control panel battery																					
Control panel battery									R									R			
Frequency converter frames R6 to R9																					
DC circuit electrolytic capacitors and discharging resistors									R									R			
Module internal circuit boards ZINT, ZPOW, ZINP												R									
DC busbar									R									R			
Frequency converter frames R10 to R11																					
Flat ribbon cables												R									
DC circuit electrolytic capacitors and discharging resistors									R									R			
Module internal circuit boards BPOW / ZPOW												R									
Module internal circuit boards BFPS, BGDR, ZBDR, ZINT												R									

Legend

- I Inspection (visual inspection and maintenance action if needed)
- P Performance of on/off-site work (commissioning, tests, measurements, or other work)
- R Replacement